

National Load Despatch Centre
Import of Jharkhand Transfer Capability for October 2021

Issue Date: 26th September 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2021 to 31st October 2021	00-24	1456	57	1399	847.52	551		TOTAL GENERATION 533 MW, total load 1933 MW
Limiting Constraints		132 kV Maithon-Jamtara and 132 kV Adityapur-Rajkarswan						