

National Load Despatch Centre
Import of Jharkhand Transfer Capability for September 2021

Issue Date: 26th August 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2021 to 30th September 2021	00-24	1421	51	1370	841.64	528		TOTAL GENERATION 528 MW, total load 1896 MW
Limiting Constraints		132 kV Maithon-Jamtara and 132 kV Adityapur-Rajkarswan						