

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for October 2021**

**Issue Date: 28th Sep 2021**

**Issue Time: 2000 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Oct 2021 to 31st Oct 2021</b>	00 - 18	148	5	143	4	139	-	
	18- 22	152	5	147	4	143	-	
	22 - 24	148	5	143	4	139	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						