

POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE

URGENT MARKET INFORMATION

Date of Issue: 11-June-2012

Time of Issue: 15:00 Hrs

The TTC/ATC of ER-NER corridor is revised due to the S/D of the following elements:

1. 400 kV Balipara - Bongaigaon Ckt I from. 0800 Hr to 1600 Hr (Day Time) from 12.06.12 to 19.06.12
2. 400 kV Balipara - Bongaigaon Ckt II from 0800 Hr to 1600 Hr (Day Time) from 20.06.12 to 27.06.12
3. 400kV Malda- Purnea D/C- 07:00 hrs of 30/05/2012 to 16:00 hrs of 23/06/2012 on continuous basis due to modification & stringing work at Loc No. 71 & 72.
4. 400kV Bongaigaon-New Siliguri II from 10:00 hrs. to 16:00 hrs. on 12-06-12 for stringing of earth wire.

1. From 12/06/2012 to 22/06/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-08:00	600	200	35	365
	08:00-17:00	380	200	35	145
	17:00-23:00	550	200	35	315
	23:00-24:00	600	200	35	365
NER→ER	00:00-08:00	570	0	100	470
	08:00-17:00	180	0	100	80
	17:00-24:00	570	0	100	470

2. From 23/06/2012 to 27/06/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-08:00	600	200	35	365
	08:00-17:00	380	200	35	145
	17:00-24:00	600	200	35	365
NER→ER	00:00-08:00	570	0	100	470
	08:00-17:00	180	0	100	80
	17:00-24:00	570	0	100	470