

POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE

URGENT MARKET INFORMATION

Date of Issue: 20th-June-2012

Time of Issue: 12:00 Hrs

The TTC/ATC of ER-NER corridor is revised due to improved hydro generation at Teesta & Tala Power Station.

The following element is already under S/D.

1. 400 kV Balipara - Bongaigaon Ckt II from 0800 Hr to 1600 Hr (Day Time) from 20.06.12 to 27.06.12

1. From 20/06/2012 to 27/06/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM- LTOA	Limiting constrains
ER→NER	00:00-08:00	600	200	35	365	
	08:00-17:00	380	200	35	145	400 kV Balipara – Bongaigaon Ckt I 220 kV BTPS - Agia S/C
	17:00-24:00	600	200	35	365	
NER→ER	00:00-08:00	570	0	100	470	
	08:00-17:00	180	0	100	80	400 kV Balipara – Bongaigaon Ckt I 220 kV Sarusajai - Boko S/C
	17:00-24:00	570	0	100	470	