

NER-Generation Outages Details

Important: Generation Outages from 00:00 Hrs. to 23:59 Hrs. only need to be included in the Report.

Report for Date :			29-Aug-2014			Date of Reporting :			30-Aug-2014		
A. Planned Outages											
Central Sector (CS)											
Sl No	Station	State	Agency	Unit No	Capacity	Reason(s)	Outage		Expected Revival Date		
					(MW)		Date	Time			
1	Kopili	ASSAM	NEEPCO	3	50	S/D AVAILED BY NEEPCO	22-Jan-2014	0807	31-Aug-2014		
2	Khandong	ASSAM	NEEPCO	2	25	S/D AVAILED BY NEEPCO	12-Mar-2014	1401	31-Aug-2014		
3	Palatana GTG	TRIPURA	OTPC	1	232.3	S/D AVAILED BY OTPC	20-Aug-2014	1130	04-Sep-2014		
4	Palatana STG	TRIPURA	OTPC	1	131	S/D AVAILED BY OTPC	20-Aug-2014	1104	04-Sep-2014		
5											
6											
Sub Total (CS)					438.3						
State Sector (SS)											
SL.No	Station	State	Agency	Unit No	Capacity	Reason(s)	Outage		Expected Revival Date		
					(MW)		Date	Time			
1	CTPS	Assam	APGCL	1& 2	60	S/D	01-Jul-1998	0000	not yet furnished		
2	Rokhia	Tripura	TSECL	5	8	S/D for major maintenance work	31-Jan-2007	0915	Less possibility to revive		
3	Rokhia	Tripura	TSECL	3	8	S/D for major maintenance work	16-Mar-2011	1328	Less possibility to revive		
4	Gumti	Tripura	TSECL	1	5	S/D due to vibration of turbine guide bearing	06-Jun-2010	0145	not yet furnished		
5	Umtru	Meghalaya	MeECL	1	2.8	S/D, Insulation failure	11-Feb-2011	1300	not yet furnished		
6	Umtru	Meghalaya	MeECL	3	2.8	S/D, Stator problem	11-Jul-2010	1824	not yet furnished		
7	Bairabi	Mizoram	Mizoram	1	5.73	S/D for major maintenance work	27-Feb-2011	0000	not yet furnished		
8	Bairabi	Mizoram	Mizoram	2	5.73	S/D for major maintenance work	27-Feb-2011	0000	not yet furnished		
9	Bairabi	Mizoram	Mizoram	3	5.73	S/D for major maintenance work	27-Feb-2011	0000	not yet furnished		
10	Bairabi	Mizoram	Mizoram	4	5.73	S/D for major maintenance work	27-Feb-2011	0000	not yet furnished		
11											
12											
13											
Sub Total (SS)					110						
Total Planned Outages (CS+SS)					548						
B. Forced Outages											
Central Sector (CS)											
SL.No	Station	State	Agency	Unit No	Capacity	Reason(s)	Outage		Expected Revival Date		
					(MW)		Date	Time			
1	AGBPP	ASSAM	NEEPCO	6	35	E/S/D AVAILED BY NEEPCO	04-May-2014	0015	31-Aug-2014		
Sub Total (CS)					35.0						
State Sector (SS)											
SL.No	Station	State	Agency	Unit No	Capacity	Reason(s)	Outage		Expected Revival Date		
					(MW)		Date	Time			
1											
2											
3											
4											
5											
6											
Sub Total (SS)					0						
Total Forced Outages (CS+SS)					35.0						
					0						