

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability

Mar-24

Issue Date: 31th Jan 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Mar to 31th Mar 2024	00 - 17	215	5	210	134	76	-	
1st Mar to 31th Mar 2024	17 - 21	220	5	215	134	81	-	
1st Mar to 31th Mar 2024	21 - 24	215	5	210	134	76	-	
Limiting Constraints:N-1 of 132 kV Pare - Nirjuli and limiting observed at 132 kV Ranganadi-Lekhi S/C								

National Load Despatch Centre
Import of Nagaland Transfer Capability

Mar-24

Issue Date: 31th Jan 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Mar to 31th Mar 2024	00 - 17	260	5	255	134	121	-	
	17 - 21	295	5	290	134	156	-	
	21 - 24	260	5	255	134	121	-	
Limiting Constraints		N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III						

**National Load Despatch Centre
Import of Assam Transfer Capability**

Mar-24

Issue Date: 31th Jan 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Mar to 31th Mar 2024	00 - 17	1775	40	1735	1529	206	-	
	17 - 21	1715	40	1675	1529	146	-	
	21 - 24	1775	40	1735	1529	206	-	
Limiting Constraints	N-1 of 220 kV Balipara-Sonabil I or II and Limiting constraint observed at 220 kV Balipara-Sonabil II or I							

**National Load Despatch Centre
Import of Manipur Transfer Capability**

Mar-24

Issue Date: 31th Jan 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Mar to 31th Mar 2024	00 - 17	310	5	305	204	101	-	
	17 - 21	310	5	305	204	101	-	
	21 - 24	310	5	305	204	101	-	
Limiting Constraints		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

National Load Despatch Centre
Import of Meghalaya Transfer Capability

Mar-24

Issue Date: 31th Jan 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Mar to 31th Mar 2024	00 - 17	370	10	360	238	122	-	
	17 - 21	300	10	290	238	52	-	
	21 - 24	370	10	360	238	122	-	
Limiting Constraints		N-1 of 132 kV Umiam 1-1 - Mawlai & limiting constraint observed at 132 kV Umiam 1-1-Umiam-1						

National Load Despatch Centre
Import of Tripura Transfer Capability

Mar-24

Issue Date: 31th Jan 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Mar to 31th Mar 2024	00 - 17	335	6	329	311	18	-	
	17 - 21	320	6	314	311	3	-	
	21 - 24	335	6	329	311	18	-	
Limiting Constraints		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						