

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability

May-25

Issue Date: 28th June 2024

Issue Time: 18:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | GNA | Margin Available for T-GNA | Changes in TTC w.r.t. Last Revision | Comments |
|--------------------------|---------------------------------|--|---------------------------|--|------------|-----------------------------------|--|-----------------|
| 1st May to 31st May 2025 | 00 - 24 | 255 | 5 | 250 | 225 | 25 | - | |

Limiting Constraints:N-1 of 132 kV Pare - Nirjuli and limiting observed at 132 kV Ranganadi-Lekhi S/C

National Load Despatch Centre
Import of Nagaland Transfer Capability

May-25

Issue Date: 28th June 2024

Issue Time: 18:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | GNA | Margin Available for T-GNA | Changes in TTC w.r.t. Last Revision | Comments |
|-----------------------------|--------------------------|--|--------------------|-------------------------------------|-----|----------------------------|-------------------------------------|----------|
| 1st May to 31st May 2025 | 00 - 24 | 260 | 5 | 255 | 145 | 110 | - | |
| Limiting Constraints | | N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III | | | | | | |

National Load Despatch Centre
Import of Assam Transfer Capability

May-25

Issue Date: 28th June 2024

Issue Time: 18:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | GNA | Margin Available for T-GNA | Changes in TTC w.r.t. Last Revision | Comments |
|--------------------------|--|---------------------------------|--------------------|-------------------------------------|------|----------------------------|-------------------------------------|----------|
| 1st May to 31st May 2025 | 00 - 24 | 2100 | 40 | 2060 | 1900 | 160 | - | |
| | N-1 of 220 kV Balipara-Sonabil I or II and Limiting constraint observed at 220 kV Balipara-Sonabil II or I | | | | | | | |

**National Load Despatch Centre
Import of Manipur Transfer Capability**

May-25

Issue Date: 28th June 2024

Issue Time: 18:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | GNA | Margin Available for T-GNA | Changes in TTC w.r.t. Last Revision | Comments |
|-----------------------------|--------------------------|--|--------------------|-------------------------------------|-----|----------------------------|-------------------------------------|----------|
| 1st May to 31st May 2025 | 00-24 | 310 | 5 | 305 | 204 | 101 | - | |
| Limiting Constraints | | N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III | | | | | | |

National Load Despatch Centre
Import of Meghalaya Transfer Capability

May-25

Issue Date: 28th June 2024

Issue Time: 18:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | GNA | Margin Available for T-GNA | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------|---------------------------------|---|---------------------------|--|------------|-----------------------------------|--|-----------------|
| 1st May to 31st May 2025 | 00 - 18 | 370 | 10 | 360 | 238 | 122 | - | |
| | 18 - 22 | 340 | 10 | 320 | 238 | 82 | - | |
| | 22 - 24 | 370 | 10 | 360 | 238 | 122 | - | |
| Limiting Constraints | | N-1 of 132 kV Umiam 1-1 - Mawlai & limiting constraint observed at 132 kV Umiam 1-1-Umiam-1 | | | | | | |

National Load Despatch Centre
Import of Tripura Transfer Capability

May-25

Issue Date: 28th June 2024

Issue Time: 18:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | GNA | Margin Available for T-GNA | Changes in TTC w.r.t. Last Revision | Comments |
|-----------------------------|---|---------------------------------|--------------------|-------------------------------------|-----|----------------------------|-------------------------------------|----------|
| 1st May to 31st May 2025 | 00 - 18 | 335 | 6 | 329 | 311 | 18 | - | |
| | 18 - 22 | 320 | 6 | 314 | 311 | 3 | - | |
| | 22 - 24 | 335 | 6 | 329 | 311 | 18 | - | |
| Limiting Constraints | N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C | | | | | | | |