

**National Load Despatch Centre**  
**Import of Arunachal Pradesh Transfer Capability for January 2022**

Issue Date: 30th Dec 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2022 to 31st Jan 2022	00 - 17	180	5	175	6	169	-	
	17 - 21	180	5	175	6	169	-	
	21 - 24	180	5	175	6	169	-	

**Limiting Constraints:N-1 of 132 kV Naharlagun - Pare and limiting observed at 132 kV Pare - Itanagar S/C**

**National Load Despatch Centre**  
**Import of Assam Transfer Capability for January 2022**

Issue Date: 30th Dec 2021

Issue Time: 1300 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2022 to 31st Jan 2022	00 - 17	1585	40	1545	271	1274	-	
	17 - 21	1550	40	1510	271	1239	-	
	21 - 24	1585	40	1545	271	1274	-	
<b>Limiting Constraints</b>	N-1 of 220/132 kV,160 MVA ICT at BTPS and Limiting constraint observed at 220/132 kV, 160 MVA ICT at BTPS							

**National Load Despatch Centre**  
**Import of Manipur Transfer Capability for January 2022**

Issue Date: 30th Dec 2021

Issue Time: 1300 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2022 to 31st Jan 2022	00 - 17	330	5	325	0	325	-	
	17 - 21	320	5	315	0	315	-	
	21 - 24	330	5	325	0	325	-	
<b>Limiting Constraints</b>		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

**National Load Despatch Centre**  
**Import of Meghalaya Transfer Capability for January 2022**

**Issue Date: 30th Dec 2021**

**Issue Time: 1300 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Jan 2022 to 31st Jan 2022</b>	00 - 17	320	10	310	39	271	-	
	17 - 21	260	10	250	39	211	-	
	21 - 24	320	10	310	39	271	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Umiam3 – Umiam1 I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam 1 II						

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for January 2022**

**Issue Date: 30th Dec 2021**

**Issue Time: 1300 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Jan 2022 to 31st Jan 2022</b>	00 - 17	148	5	143	4	139	-	
	17 - 21	152	5	147	4	143	-	
	21 - 24	148	5	143	4	139	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for January 2022**

**Issue Date: 30th Dec 2021**

**Issue Time: 1300 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Jan 2022 to 31st Jan 2022</b>	00 - 17	170	5	165	13	152	-	
	17 - 21	180	5	175	13	162	-	
	21 - 24	170	5	165	13	152	-	
<b>Limiting Constraints</b>		N-1 of 220/132 kV ,100 MVA Dimapur ICT and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICTs						

**National Load Despatch Centre**  
**Import of Tripura Transfer Capability for January 2022**

**Issue Date: 30th Dec 2021**

**Issue Time: 1100 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Jan 2022 to 31st Jan 2022</b>	00 - 17	365	6	359	0	359	-	
	17 - 21	310	6	304	0	304	-	
	21 - 24	365	6	359	0	359	-	
<b>Limiting Constraints</b>		N-1 of 132 kV SM-Nagar (TR) -SM Nagar(ISTS) S/C and limiting element observed is 132 kV PK-Bari (TR)- PK Bari (ISTS) S/C						