

**National Load Despatch Centre**  
**Import of Arunachal Pradesh Transfer Capability for Apr 2024**

Issue Date: 31th Mar 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Apr 2024 to 30th Apr 2024	00 - 17	215	5	210	134	76	-	
	17 - 21	220	5	215	134	81	-	
	21 - 24	215	5	210	134	76	-	

**Limiting Constraints:N-1 of 132 kV Pare - Nirjuli and limiting observed at 132 kV Ranganadi-Lekhi S/C**

**National Load Despatch Centre**  
**Import of Assam Transfer Capability for Apr 2024**

**Issue Date: 31th Mar 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>GNA</b>	<b>Margin Available for T-GNA</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Apr 2024 to 30th Apr 2024</b>	00 - 17	2100	40	2060	1900	160	-	
	17 - 21	2100	40	2060	1900	160	-	
	21 - 24	2100	40	2060	1900	160	-	
<b>Limiting Constraints</b>	N-1 of 400 kV Bongaigaon Azara and Limiting constraint observed at 220 kV Balipara-Sonabil I & II							

**National Load Despatch Centre**  
**Import of Manipur Transfer Capability for Apr 2024**

Issue Date: 31th Mar 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Apr 2024 to 30th Apr 2024	00 - 17	310	5	305	204	101	-	
	17 - 21	310	5	305	204	101	-	
	21 - 24	310	5	305	204	101	-	
<b>Limiting Constraints</b>		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

**National Load Despatch Centre**  
**Import of Meghalaya Transfer Capability for Apr 2024**

**Issue Date: 31th Mar 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Apr 2024 to 30th Apr 2024	00 - 17	370	10	360	238	122	-	
	17 - 21	300	10	290	238	52	-	
	21 - 24	370	10	360	238	122	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Umiam 1-1 - Mawlai & limiting constraint observed at 132 kV Umiam 1-1-Umiam-1						

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for Apr 2024**

**Issue Date: 31th Mar 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
<b>1st Apr 2024 to 30th Apr 2024</b>	00 - 17	155	5	150	95	55	-	
	17 - 21	145	5	140	95	45	-	
	21 - 24	155	5	150	95	55	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for Apr 2024**

**Issue Date: 31th Mar 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Apr 2024 to 30th Apr 2024	00 - 17	260	5	255	134	121	-	
	17 - 21	295	5	290	134	156	-	
	21 - 24	260	5	255	134	121	-	

**Limiting Constraints**

N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III

**National Load Despatch Centre**  
**Import of Tripura Transfer Capability for Apr 2024**

**Issue Date: 31th Mar 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st Apr 2024 to 30th Apr 2024	00 - 17	335	6	329	311	18	-	
	17 - 21	320	6	314	311	3	-	
	21 - 24	335	6	329	311	18	-	
<b>Limiting Constraints</b>		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						