

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for June 2022

Issue Date: 30th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 30th June 2022	00 - 18	195	5	190	6	184	-	
	18 - 22	195	5	190	6	184	-	
	22 - 24	195	5	190	6	184	-	

Limiting Constraints: N-1 of 132 kV Pare - Itanagar and limiting observed at 132 kV Naharlagun - Pare S/C

National Load Despatch Centre
Import of Assam Transfer Capability for June 2022

Issue Date: 30th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 30th June 2022	00 - 18	1555	40	1515	271	1244	-	
	18 - 22	1520	40	1480	271	1209	-	
	22 - 24	1555	40	1515	271	1244	-	
Limiting Constraints	N-1 of 220/132 kV, 160 MVA ICT at BTPS and Limiting constraint observed at 220/132 kV, 160 MVA ICT at BTPS							

National Load Despatch Centre
Import of Manipur Transfer Capability for June 2022

Issue Date: 30th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 30th June 2022	00 - 18	320	5	315	52	263	-	
	18 - 22	320	5	315	52	263	-	
	22 - 24	320	5	315	52	263	-	
Limiting Constraints		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

National Load Despatch Centre
Import of Meghalaya Transfer Capability for June 2022

Issue Date: 30th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 30th June 2022	00 - 18	320	10	310	79	231	-	
	18 - 22	260	10	250	79	171	-	
	22 - 24	320	10	310	79	231	-	
Limiting Constraints		N-1 of 132 kV Umiam3 – Umiam1 I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam 1 II						

National Load Despatch Centre
Import of Mizoram Transfer Capability for May 2022

Issue Date: 30th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 30th June 2022	00 - 18	165	5	160	22	138	-	
	18 - 22	160	5	155	22	133	-	
	22 - 24	165	5	160	22	138	-	
Limiting Constraints		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

National Load Despatch Centre
Import of Nagaland Transfer Capability for June 2022

Issue Date: 30th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 30th June 2022	00 - 18	215	5	210	27	183	-	
	18 - 22	255	5	250	27	223	-	
	22 - 24	215	5	210	27	183	-	
Limiting Constraints		N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III						

National Load Despatch Centre
Import of Tripura Transfer Capability for May 2022

Issue Date: 30th May 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 30th June 2022	00 - 18	360	6	354	196	158	-	
	18 - 22	320	6	314	196	118	-	
	22 - 24	360	6	354	196	158	-	
Limiting Constraints		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						