




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

06/06/14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.64	9.16	19.46	37.94	26.42	5.23	0.14	30.28	55.05	14.68	9.34	98.21	23.88

Average Frequency	49.94	Frequency Variation Index :	0.145	Standard Deviation :	0.107
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.221	18:03:00	Max	50.158	18:15:00
Min	49.47	11:19:50	Min	49.703	11:30:00