




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for 17-05-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	6.38	15.45	24.16	23.10	23.08	6.57	1.25	46.02	35.86	18.13	10.36	92.37	15.58

Average Frequency		49.91	Frequency Variation Index :		0.274	Standard Deviation :		0.142
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.31	6:01:20	Max	50.255	6:15:00
Min	49.48	22:34:10	Min	49.550	22:45:00