




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for 22-05-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.36	5.92	20.05	38.84	28.17	5.57	1.09	26.34	57.07	16.59	9.99	98.55	22.88

Average Frequency		49.96	Frequency Variation Index :		0.117	Standard Deviation :		0.100
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.3	6:08:10	Max	50.238	6:15:00
Min	49.66	14:37:20	Min	49.771	14:45:00