

National Load Despatch Centre
Import Capability of Punjab for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	9500	500	9000	5497	3503		https://www.punjab.sldc.org/ATC_TTC.aspx
Limiting Constraints		N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						

National Load Despatch Centre
Import Capability of Uttar Pradesh for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	16100	600	15500	9779	5721		https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Azamgarh, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

National Load Despatch Centre
Import Capability of Haryana for January 2024

Issue Date: - 22/01/2024

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	9100	250	8850	5418	3432		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICTs at Deepalpur and Panipat(BBMB)						

National Load Despatch Centre
Import Capability of Rajasthan for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	7600	600	7000	5689	1311		https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads
Limiting Constraints		N-1 contingency of 400/220kV Chittorgarh, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Bhinmal ICTs						

National Load Despatch Centre
Import Capability of Delhi for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	7300	300	7000	4810	2190		https://www.delhisldc.org/resources/atcttcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

National Load Despatch Centre
Import Capability of HP for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	1680	100	1580	1130	450		https://hpsldc.com/mrm_category/ttc-atc-report/
Limiting Constraints		High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kunihar transformers						

National Load Despatch Centre
Import Capability of Uttarakhand for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	1700	100	1600	1402	198		https://uksldc.in/ttc-atc
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

National Load Despatch Centre
Import Capability of J&K for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	2900	100	2800	1977	823		
Limiting Constraints		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora						

National Load Despatch Centre
Import Capability of Chandigarh for January 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-24	400	20	380	342	38		
Limiting Constraints		N-1 contingency of 220kV Nallagarh-Kishengarh						