National Load Despatch Centre Import Capability of Punjab for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	10300	500	9800	5497	4303		https://www.punjab sldc.org/ATC_TTC.as px
Limiting Constr	aints	N-1 contigency of 400, Loading close to N-1 c 220 kV underlying net	ontingency limits of 40	00/220kV Patran, Male				

National Load Despatch Centre Import Capability of Uttar Pradesh for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	17300	600	16700	10165	6535		https://www.upsldc.or g/documents/20182/0/ ttc_atc_24-11- 16/4c79978e-35f2- 4aef-8c0f- 7f30d878dbde
Limiting Con	straints	N-1 contingency o	f 400/220kV Obra,	Allahabad(PG), Go	rakhpur (UP), Agra	(PG), Lucknow (PG) ICT:	5	

National Load Despatch Centre Import Capability of Haryana for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	10300	300	10000	5418	4582		https://hvpn.org. in/#/atcttc
Limiting Con	straints	N-1 contingency o	f 400/220kV ICT at	Deepalpur, Hisar,	Kabulpur and Panipat(ВВМВ)		

National Load Despatch Centre Import Capability of Rajasthan for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	7600	600	7000	5755	1245		https://sldc.rajas than.gov.in/rrvpn l/scheduling/dow nloads
Limiting Con	straints	N-1 contingency o	f 400/220kV Heera	pura, Jodhpur, Bik	aner, Ajmer, Merta, F	lindaun and Ratan	garh ICTs	

National Load Despatch Centre Import Capability of Delhi for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments		
1st January 2026 to 31th January 2026	00-24	7300	300	7000	4810	2190		https://www.del hisldc.org/resour ces/atcttcreport. pdf		
Limiting Constra	aints	N-1 contingency o	N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.							

National Load Despatch Centre Import Capability of Uttarakhand for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	1710	100	1610	1402	208		https://uksldc.in/ttc- atc
Limiting Constr	aints	N-1 contingency of 40	0/220kV Kashipur ICT:	s. High loading of 220k	V Roorkee-Roorkee an	d 220kV CBGanj-Pantn	agar lines	

National Load Despatch Centre Import Capability of HP for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	2386	100	2286	1130	1156		https://hpsldc.com/ mrm_category/ttc- atc-report/
Limiting Constraints Overloading of 2			MVA Giri transformers	5				

National Load Despatch Centre Import Capability of J&K for January 2026

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	3500	100	3400	1977	1423		
Limiting Constr		N-1 contigency of 400, 220 kV underlying net		•	gar			

National Load Despatch Centre Import Capability of Chandigarh for January 2026

Issue Time: 1600 Issue Date: -25-01-2025 Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2026 to 31th January 2026	00-24	400	20	380	342	38		
Limiting Constr		N-1 contigency of 220	kV Nallagarh-Kishenga	nrh				