

**National Load Despatch Centre**  
**Import Capability of Punjab for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2026 to 31st March 2026	00-24	10600	500	10100	5497	4603		<a href="https://www.punjab.sldc.org/ATC_TTC.aspx">https://www.punjab.sldc.org/ATC_TTC.aspx</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICT at Rajpura, Ludhiana, Jalandhar, Muktsar Loading close to N-1 contingency limits of 400/220kV Malerkotla and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						

**National Load Despatch Centre**  
**Import Capability of Uttar Pradesh for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2026 to 31st March 2026	00-24	17300	600	16700	10165	6535		<a href="https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Agra(PG), Lucknow (PG) ICTs						

**National Load Despatch Centre**  
**Import Capability of Haryana for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2026 to 31st March 2026	00-24	10300	300	10000	5418	4582		<a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB)						

**National Load Despatch Centre**  
**Import Capability of Rajasthan for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2026 to 31st March 2026	00-24	7600	600	7000	5755	1245		<a href="https://sldc.rajabharat.gov.in/rrvpn/scheduling/downloads">https://sldc.rajabharat.gov.in/rrvpn/scheduling/downloads</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs						

**National Load Despatch Centre  
Import Capability of Delhi for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2026 to 31st March 2026	00-24	7300	300	7000	4810	2190		<a href="https://www.delhisldc.org/resources/atcttcreport.pdf">https://www.delhisldc.org/resources/atcttcreport.pdf</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

**National Load Despatch Centre**  
**Import Capability of Uttarakhand for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2026 to 31st March 2026	00-24	1710	100	1610	1402	208		<a href="https://uksldc.in/ttc-atc">https://uksldc.in/ttc-atc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

**National Load Despatch Centre**  
**Import Capability of HP for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2026 to 31st March 2026	00-24	2386	100	2286	1130	1156		<a href="https://hpsldc.com/mrm_category/ttc-atc-report/">https://hpsldc.com/mrm_category/ttc-atc-report/</a>
<b>Limiting Constraints</b>		Overloading of 2*100MVA Giri transformers						

**National Load Despatch Centre**  
**Import Capability of J&K for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2026 to 31st March 2026	00-09 & 14-24	3500	100	3400	1977	1423		
	09-14	2800	100	2700	1977	723		
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora Low voltages in J&K control area due to high MVAR drawl						

**National Load Despatch Centre**  
**Import Capability of Chandigarh for March 2026**

Issue Date: -28th March 25

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2026 to 31st March 2026	00-24	400	20	380	342	38		
<b>Limiting Constraints</b>		N-1 contingency of 220kV Nallagarh-Kishengarh						