

**National Load Despatch Centre**  
**Import Capability of Punjab for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| Date                                    | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW)   | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments  |
|---|--------------------------|--|-------------------------|--|--------------------------------------|---|-------------------------------------|---|
| 1st November 2023 to 30th November 2023 | 00-24                    | 9500   | 500                     | 9000                                     | 5497                                 | 3503  |                                     | <a href="https://www.punjab.sldc.org/ATC_TTC.aspx">https://www.punjab.sldc.org/ATC_TTC.aspx</a> |
| <b>Limiting Constraints</b>             |                          | N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar<br>Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs<br>220 kV underlying network at Jalandhar, Ludhiana and Amritsar |                         |  |                                      |   |                                     |   |

**National Load Despatch Centre**  
**Import Capability of Uttar Pradesh for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| <b>Date</b>                             | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC) (MW)</b>  | <b>Reliability Margin (MW)</b> | <b>Available Transfer Capability (ATC) (MW)</b> | <b>Approved General Network Access (MW)</b> | <b>Margin Available for Temporary General Network Access(MW)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b>   |
|---|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st November 2023 to 30th November 2023 | 00-24                           | 16100  | 600                            | 15500   | 10165                                       | 5335   |  | <a href="https://www.upslc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upslc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a> |
| <b>Limiting Constraints</b>             |                                 | N-1 contingency of 400/220kV Azamgarh, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs |                                |   |   |  |  |   |

**National Load Despatch Centre**  
**Import Capability of Haryana for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| <b>Date</b>                             | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC) (MW)</b>                                       | <b>Reliability Margin (MW)</b> | <b>Available Transfer Capability (ATC) (MW)</b> | <b>Approved General Network Access (MW)</b> | <b>Margin Available for Temporary General Network Access(MW)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b>   |
|---|---------------------------------|---|--------------------------------|---|---|--|--|---|
| 1st November 2023 to 30th November 2023 | 00-24                           | 9100  | 250                            | 8850  | 5418  | 3432   |  | <a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a> |
| <b>Limiting Constraints</b>             |                                 | N-1 contingency of 400/220kV ICTs at Deepalpur, Panipat(BBMB) and Kurukshetra(PG) |                                |   |   |  |  |   |

**National Load Despatch Centre**  
**Import Capability of Rajasthan for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| <b>Date</b>                             | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC) (MW)</b>  | <b>Reliability Margin (MW)</b> | <b>Available Transfer Capability (ATC) (MW)</b> | <b>Approved General Network Access (MW)</b> | <b>Margin Available for Temporary General Network Access(MW)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b>   |
|---|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st November 2023 to 30th November 2023 | 00-24                           | 7600   | 600                            | 7000  | 5755  | 1245   |  | <a href="https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads">https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads</a> |
| <b>Limiting Constraints</b>             |                                 | N-1 contingency of 400/220kV Chittorgarh, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Bhinmal ICTs |                                |   |   |  |  |   |

**National Load Despatch Centre**  
**Import Capability of Delhi for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| <b>Date</b>                             | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC) (MW)</b>                                  | <b>Reliability Margin (MW)</b> | <b>Available Transfer Capability (ATC) (MW)</b> | <b>Approved General Network Access (MW)</b> | <b>Margin Available for Temporary General Network Access(MW)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b>   |
|---|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st November 2023 to 30th November 2023 | 00-24                           | 7300   | 300                            | 7000  | 4810  | 2190   |  | <a href="https://www.delhisldc.org/resources/atctcreport.pdf">https://www.delhisldc.org/resources/atctcreport.pdf</a> |
| <b>Limiting Constraints</b>             |                                 | N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs. |                                |   |   |  |  |   |

**National Load Despatch Centre**  
**Import Capability of HP for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| Date                                    | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW)  | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments  |
|---|--------------------------|---|-------------------------|--|--------------------------------------|---|-------------------------------------|---|
| 1st November 2023 to 30th November 2023 | 00-24                    | 1400  | 100                     | 1300                                     | 1130                                 | 170   |                                     | <a href="https://hpsldc.com/mrm_category/ttc-atc-report/">https://hpsldc.com/mrm_category/ttc-atc-report/</a> |
| <b>Limiting Constraints</b>             |                          | N-1 contingency of 400/220kV Nallagarh ICTs. High loading of 220kV Nallagarh-Upernangal D/C |                         |  |                                      |   |                                     |   |

**National Load Despatch Centre**  
**Import Capability of Uttarakhand for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| Date                                    | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW)   | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments  |
|---|--------------------------|--|-------------------------|--|--------------------------------------|---|-------------------------------------|---|
| 1st November 2023 to 30th November 2023 | 00-24                    | 1700   | 100                     | 1600                                     | 1402                                 | 198   |                                     | <a href="https://uksldc.in/ttc-atc">https://uksldc.in/ttc-atc</a> |
| <b>Limiting Constraints</b>             |                          | N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines |                         |  |                                      |   |                                     |   |

**National Load Despatch Centre**  
**Import Capability of J&K for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| Date                                    | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW)  | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|---|-------------------------|--|--------------------------------------|---|-------------------------------------|----------|
| 1st November 2023 to 30th November 2023 | 00-24                    | 2500  | 100                     | 2400                                     | 1977                                 | 423   |                                     |          |
| <b>Limiting Constraints</b>             |                          | N-1 contingency of 400/220KV ICTs at Amargarh<br>220 kV underlying network at Amargarh, Wagoora |                         |  |                                      |   |                                     |          |



**National Load Despatch Centre**  
**Import Capability of Chandigarh for November 2023**

Issue Date: - 28-10-2023

Issue Time: 1600

Revision No. 0

| <b>Date</b>                             | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC) (MW)</b>   | <b>Reliability Margin (MW)</b> | <b>Available Transfer Capability (ATC) (MW)</b> | <b>Approved General Network Access (MW)</b> | <b>Margin Available for Temporary General Network Access(MW)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b> |
|---|---------------------------------|---|--------------------------------|---|---|--|--|-----------------|
| 1st November 2023 to 30th November 2023 | 00-24                           | 400   | 20                             | 380   | 342   | 38   |  |                 |
| <b>Limiting Constraints</b>             |                                 | N-1 contingency of 220kV Nallagarh-Kishengarh |                                |   |   |  |  |                 |