

National Load Despatch Centre
Import Capability of Uttar Pradesh for

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February to 28th February	00-24	16500	600	15900	9779	6121		https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef
Limiting Constraints		N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

**National Load Despatch Centre
Import Capability of Haryana for**

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
Ist February to 28th February	00-24	10300	300	10000	5418	4582		https://hvpn.org.in/#/atcttc
Limiting Constraints	N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB)							

National Load Despatch Centre
Import Capability of Rajasthan for

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February to 28th February	00-24	7600	600	7000	5689	1311		https://sldc.rajasthan.gov.in/rrvpnl/scheduling/download
Limiting Constraints		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs						

National Load Despatch Centre
Import Capability of Delhi for

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February to 28th February	00-24	7300	300	7000	4810	2190		https://www.delhisidc.org/resources/atcttcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

**National Load Despatch Centre
Import Capability of Uttarakhand for**

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February to 28th February	00-24	1800	100	1700	1402	298		https://uksldc.in/ttc-atc
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

**National Load Despatch Centre
Import Capability of HP for**

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February to 28th February	00-24	850	100	750	1130	0		https://hpsldc.com/mrm_category/ttc-atc-report/
Limiting Constraints		High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kunihar transformers						

**National Load Despatch Centre
Import Capability of J&K for**

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February to 28th February	00-24	2500	100	2400	1977	423		
Limiting Constraints	N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora							

**National Load Despatch Centre
Import Capability of Chandigarh for**

February-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February to 28th February	00-24	400	20	380	342	38		
Limiting Constraints		N-1 contingency of 220kV Nallagarh-Kishengarh						