

**National Load Despatch Centre
Import Capability of Uttar Pradesh for**

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st March to 31th March 2025 | 00-24 | 16500 | 600 | 15900 | 9779 | 6121 | | https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef |
| Limiting Constraints | | N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs | | | | | | |

National Load Despatch Centre
Import Capability of Haryana for

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---------------------------------|--|--------------------------------|---|---|--|--|---|
| Ist March to 31th March 2025 | 00-24 | 10300 | 300 | 10000 | 5418 | 4582 | | https://hvpn.org.in/#/atcttc |
| Limiting Constraints | | N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB) | | | | | | |

**National Load Despatch Centre
Import Capability of Rajasthan for**

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st March to 31th March 2025 | 00-24 | 7600 | 600 | 7000 | 5689 | 1311 | | https://sldc.rajasthan.gov.in/rrvpnl/scheduling/download |
| Limiting Constraints | | N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs | | | | | | |

**National Load Despatch Centre
Import Capability of Delhi for**

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st March to 31th March 2025 | 00-24 | 7300 | 300 | 7000 | 4810 | 2190 | | https://www.delhisidc.org/resources/atcttcreport.pdf |
| Limiting Constraints | | N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs. | | | | | | |

**National Load Despatch Centre
Import Capability of Uttarakhand for**

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st March to 31th March 2025 | 00-24 | 1800 | 100 | 1700 | 1402 | 298 | | https://uksldc.in/ttc-atc |
| Limiting Constraints | | N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines | | | | | | |

**National Load Despatch Centre
Import Capability of HP for**

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---------------------------------|---|--------------------------------|---|---|--|--|---|
| 1st March to 31th March 2025 | 00-24 | 850 | 100 | 750 | 1130 | 0 | | https://hpsldc.com/mrm_category/ttc-atc-report/ |
| Limiting Constraints | | High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kunihar transformers | | | | | | |

**National Load Despatch Centre
Import Capability of J&K for**

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---|---|--------------------------------|---|---|--|--|-----------------|
| 1st March to 31th March 2025 | 00-24 | 2500 | 100 | 2400 | 1977 | 423 | | |
| Limiting Constraints | N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora | | | | | | | |

**National Load Despatch Centre
Import Capability of Chandigarh for**

March-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|------------------------------|---------------------------------|---|--------------------------------|---|---|--|--|-----------------|
| 1st March to 31th March 2025 | 00-24 | 400 | 20 | 380 | 342 | 38 | | |
| Limiting Constraints | | N-1 contingency of 220kV Nallagarh-Kishengarh | | | | | | |