

**National Load Despatch Centre  
Import Capability of Punjab for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May to 31th May 2025	00-24	9500	500	9000	5497	3503		<a href="https://www.punjabsltdc.org/ATC_TTC.aspx">https://www.punjabsltdc.org/ATC_TTC.aspx</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICT at Rajpura, Ludhiana, Jalandhar, Muktsar Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						

**National Load Despatch Centre  
Import Capability of Uttar Pradesh for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31th May 2025	00-24	16500	600	15900	9779	6121		<a href="https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef">https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

**National Load Despatch Centre**  
**Import Capability of Haryana for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31th May 2025	00-24	10300	300	10000	5418	4582		<a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a>
<b>Limiting Constraints</b>	N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB)							

**National Load Despatch Centre  
Import Capability of Rajasthan for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31th May 2025	00-24	7600	600	7000	5689	1311		<a href="https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads">https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs						

**National Load Despatch Centre**  
**Import Capability of Delhi for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31st May 2025	00-24	7300	300	7000	4810	2190		<a href="https://www.delhisidc.org/resources/atcttcreport.pdf">https://www.delhisidc.org/resources/atcttcreport.pdf</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

**National Load Despatch Centre  
Import Capability of Uttarakhand for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31st May 2025	00-24	1800	100	1700	1402	298		<a href="https://uksldc.in/ttc-atc">https://uksldc.in/ttc-atc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

**National Load Despatch Centre**  
**Import Capability of HP for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31th May 2025	00-24	850	100	750	1130	0		<a href="https://hpsldc.com/mrm_category/ttc-atc-report/">https://hpsldc.com/mrm_category/ttc-atc-report/</a>
<b>Limiting Constraints</b>		High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kunihar transformers						

**National Load Despatch Centre  
Import Capability of J&K for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31th May 2025	00-24	2500	100	2400	1977	423		
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora						



**National Load Despatch Centre  
Import Capability of Chandigarh for**

May-25

Issue Date: -29-June-24

Issue Time: 1600

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May to 31th May 2025	00-24	400	20	380	342	38		
<b>Limiting Constraints</b>		N-1 contingency of 220kV Nallagarh-Kishengarh						