

**National Load Despatch Centre**  
**Import Capability of Uttar Pradesh for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2024 to 31st October 2024	00-24	17300	600	16700	10165	6535		<a href="https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Agra(PG), Lucknow (PG) ICTs						

**National Load Despatch Centre**  
**Import Capability of Haryana for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2024 to 31st October 2024	00-24	10300	300	10000	5418	4582		<a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB)						

**National Load Despatch Centre**  
**Import Capability of Rajasthan for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2024 to 31st October 2024	00-24	7600	600	7000	5755	1245		<a href="https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads">https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs						

**National Load Despatch Centre**  
**Import Capability of Delhi for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2024 to 31st October 2024	00-24	7300	300	7000	4810	2190		<a href="https://www.delhisldc.org/resources/atcttcreport.pdf">https://www.delhisldc.org/resources/atcttcreport.pdf</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

**National Load Despatch Centre  
Import Capability of Uttarakhand for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2024 to 31st October 2024	00-24	1700	100	1600	1402	198		<a href="https://uksldc.in/ttc-atc">https://uksldc.in/ttc-atc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

**National Load Despatch Centre**  
**Import Capability of HP for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2024 to 31st October 2024	00-24	850	100	750	1130	0		<a href="https://hpsldc.com/mrm_category/ttc-atc-report/">https://hpsldc.com/mrm_category/ttc-atc-report/</a>
<b>Limiting Constraints</b>		High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kuniyar transformers						

**National Load Despatch Centre**  
**Import Capability of J&K for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2024 to 31st October 2024	00-24	2800	100	2700	1977	723		
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICTs at Amargarh, Samba 220 kV underlying network at Amargarh, Wagoora						

**National Load Despatch Centre**  
**Import Capability of Chandigarh for October 2024**

Issue Date: - 30-09-2024

Issue Time: 1600

Revision No. 4

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2024 to 31st October 2024	00-24	400	20	380	342	38		
<b>Limiting Constraints</b>		N-1 contingency of 220kV Nallagarh-Kishengarh						