

**National Load Despatch Centre**  
**Import of Uttar Pradesh Transfer Capability for December 2021**

Issue Date: 28-11-2021

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st December 2021 to 31st December 2021	00-24	13800	600	13200	8490	4710		<a href="https://www.upsltdc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upsltdc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import of Rajasthan Transfer Capability for December 2021**

Issue Date: 28-11-2021

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st December 2021 to 31st December 2021	00-24	6200	300	5900	3400	2500		<a href="https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads">https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Chittorgarh, Jodhpur ICTs and Ajmer ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import of Haryana Transfer Capability for December 2021**

Issue Date: 28-11-2021

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st December 2021 to 31st December 2021	00-24	8500	600	7900	3000	4900		<a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV ICTs at Deepalpur and Kurukshetra(PG)						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import of Delhi Transfer Capability for December 2021**

Issue Date: 28-11-2021

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st December 2021 to 31st December 2021	00-24	6800	300	6500	4180	2320		
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Mundka and Bamnauli ICTs.						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import of HP Transfer Capability for December 2021**

Issue Date: 28-11-2021

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2021 to 31st December 2021	00-24	1200	100	1100	1400			<a href="https://hpsidc.com/mrm_category/ttc-atc-report/">https://hpsidc.com/mrm_category/ttc-atc-report/</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Nallagarh ICTs.						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages