

National Load Despatch Centre
Import Capability of Uttar Pradesh for May 2022

Issue Date: 28th April 2022

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 31st May 2022	00-24	15100	600	14500	7066	7434		https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Azamgarh, Mau, Sarnath, Lucknow (PG) ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

LTA/MTOA as per Notification of Transmission charges payable by DICs for Billing Month of April, 2022 (NLDC)

**National Load Despatch Centre
Import Capability of Rajasthan for May 2022**

Issue Date: 28th April 2022

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 31st May 2022	00-24	6200	300	5900	3404	2496		https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads
Limiting Constraints		N-1 contingency of 400/220kV Chittorgarh, Jodhpur, Bikaner, Ajmer, Merta and Bhinmal ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

LTA/MTOA as per Notification of Transmission charges payable by DICs for Billing Month of April, 2022 (NLDC)

National Load Despatch Centre
Import Capability of Haryana for May 2022

Issue Date: 28th April 2022

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 31st May 2022	00-24	8500	600	7900	3066	4834		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICTs at Deepalpur and Kurukshetra(PG)						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

LTA/MTOA as per Notification of Transmission charges payable by DICs for Billing Month of April, 2022 (NLDC)

National Load Despatch Centre
Import Capability of Delhi for May 2022

Issue Date: 28th April 2022

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 31st May 2022	00-24	6800	300	6500	3630	2870		
Limiting Constraints		N-1 contingency of 400/220kV Mundka and Bamnauli ICTs.						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

LTA/MTOA as per Notification of Transmission charges payable by DICs for Billing Month of April, 2022 (NLDC)

**National Load Despatch Centre
Import Capability of HP for May 2022**

Issue Date: 28th April 2022

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 31st May 2022	00-24	1400	100	1300	1400	-100		https://hpslhc.com/mrm_category/ttc-atc-report/
Limiting Constraints		N-1 contingency of 400/220kV Nallagarh ICTs. High loading of 220kV Nallagarh-Upernangal D/C and 220kV Hamirpur-Hamirpur D/C						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages
LTA/MTOA as per Notification of Transmission charges payable by DICs for Billing Month of April, 2022 (NLDC)

National Load Despatch Centre
Import Capability of Uttarakhand for May 2022

Issue Date: 28th April 2022

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 31st May 2022	00-24	1600	100	1500	1020	480		http://uksldc.in/transfer-capability
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages
LTA/MTOA as per Notification of Transmission charges payable by DICs for Billing Month of April, 2022 (NLDC)