## National Load Despatch Centre Import of ODISHA Transfer Capability for July 2021

Issue Date: 26th June 2021				Issue Time: 160	0 hrs	Revision No. 0		
Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2021 to 31st July 2021	00-24	2767	90	2677	1675	1002		
Limiting Constraints		N-1 contingency of 220 kV Bolangir-New Bolangir						