

National Load Despatch Centre
Import of Odisha Transfer Capability for October 2021

Issue Date: 26th September 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2021 to 31st October 2021	00-24	2442	88	2354	1674.78	679		Assumption 2166 MW as generation and 4396 MW as load
Limiting Constraints		N-1 contingency of 220 kV Rourkella tarkera d/c, Outage of OPGC unit 3 and 4, Outage of Val(sterlite) unit 3						