

POWER SYSTEM OPERATION CORPORATION
 NATIONAL LOAD DISPATCH CENTRE
 B-9, QUTUB INSTITUTIONAL AREA,
 KATWARIA SARAI, NEW DELHI- 110016

Message No: 115/088

Date: 11-06-2016 Time: 19:05 hrs

From: Shift Charge Manager, NLDC

To: SCM | NRDC | WRDC | SRDC | ERDC | NRDC

Sub: Revision of TTC/ATC on account of Tripping/ Revival of power system element.

Sr No.	Corridor	Current (MW)		Revised (MW)		Time Blocks	Reason for Revision
		TTC	ATC	TTC	ATC		
1	WR-SR	3750	3000	4000	3250	78-96	Restoration of 400kV Ramagundam-Bhadrawathi II
2	SR Import	6400	5650	6650	5900	78-96	

विनोद

SCM, NLDC