

**NATIONAL LOAD DESPATCH CENTRE**  
**URGENT MARKET INFORMATION**

Date of Issue: 12-MAR-2012

**ATC OF NER-ER Corridor FOR 13<sup>th</sup> March, 2012**

Due to shutdown of 400kV Balipara-Bongaigaon I from 0800Hrs to 1600Hrs of 13.03.12, the ATC-TTC of NER-ER corridor during the above period shall be revised as follows:

During this period, **import capability** of NER is revised as follows:

**I) Import capability of NER**

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
ER→NER	00:00-08:00	450	200	35	215
	<b>08:00-17:00</b>	<b>305</b>	<b>200</b>	<b>35</b>	<b>70</b>
	23:00-24:00	450	200	35	215
	17:00-23:00	450	200	35	215

The limiting factor in Import Capability of NER is due to following constraints –

- (N-1) contingency of 400kV Balipara-Bongaigaon II
- High loading of 220kV BTPS-Agia S/C.

During this period, **export capability** of NER is revised as follows:

**I) Export capability of NER**

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
NER→ER	00:00-08:00	570	0	100	470
	<b>08:00-17:00</b>	<b>170</b>	<b>0</b>	<b>100</b>	<b>70</b>
	23:00-24:00	570	0	100	470
	17:00-23:00	570	0	100	470

The limiting factor in Export Capability of NER is due to following constraints –

- (N-1) contingency of 400kV Balipara-Bongaigaon II
- High loading of 220kV BTPS-Agia S/C.