

Natioanal Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for August 2015

Issue Date: 20/08/2015

Issue Time: 1200 hrs

Revision No. 7

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1 st to 4 th	00:00 Hrs. -24:00 Hrs.	4205	350	3855	2619	1236		
5th	00:00 Hrs. -19:00 Hrs.				2420	1435		
	19:00 Hrs. - 24:00 Hrs.	4385		4035	2728	1307		
6th to 8th	00:00 Hrs. -24:00 Hrs.	4385		4035	2728	1307		
9th to 10th	00:00 Hrs. -24:00 Hrs.	4205		3855	2465	1390		
11th	00:00 Hrs. -16:00 Hrs.	4205		3855	2465	1390		
	16:00 Hrs. -24:00 Hrs.	4734		4384	2791	1593		
12th	00:00 Hrs. -10:00 Hrs.	4560		4210	2682	1528		
	10:00 Hrs. -24:00 Hrs.	4385		4035	2573	1462		
13th to 15th	00:00 Hrs. -24:00 Hrs.	4205		3855	2465	1390		
16th to 20th	00:00 Hrs. -24:00 Hrs.	4385		4035	2573	1462		
21st to 24th	00:00 Hrs. -24:00 Hrs.	4410		4060	2895	1165	25	Due to OCC Approved Vallur Outage and NCTPS Stage 2 Unit -2 Outage Extension
25th	00:00 Hrs. -24:00 Hrs.	4410		4060	2696	1364	25	
26 th to 27th	00:00 Hrs. -24:00 Hrs.	4225		3875	2575	1300	70	Due to NCTPS Stage 2 Unit-1 Outage Extension
28th	00:00 Hrs. -24:00 Hrs.	4225		3875	2432	1443	70	
29th	00:00 Hrs. -24:00 Hrs.	4225		3875	2509	1366	70	
30th to 31st	00:00 Hrs. -24:00 Hrs.	4225		3875	2420	1455	70	

Limiting Constraint	(n-1) contingency of 400kV Mywadi - Palakkad D/C
----------------------------	--

**National Load Despatch Centre
Total Transfer Capability for August 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	6/26/2015	01-08-2015 to 31-08-2015	Revised due to 400kV MTR - TVLM DC , NTPL Unit -1 Commissioning and KKNPP Unit - 1 Outage
2	7/20/2015	01-08-2015 to 31-08-2015	Revised due to LGBR Changes in 109th OCCM , Revised Unit Outages, NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
3	7/21/2015	01-08-2015 to 10-08-2015	Due to Outage Extension of NCTPS Stage 2 Unit -2
4	8/5/2015	06-08-2015 to 08-08-2015	Due to Outage Extension of Vallur Unit - 2
5	8/7/2015	11-08-2015 to 20-08-2015	Considering the NEW Outages as Decide in 110th OCCM , NCTPS Stage Unit 2 Outage Extension upto 20th August 2015.
6	8/11/2015	11-08-2015 to 12-08-2015	Due to Outage and revival of NTECL Unit- 1,2&3.
7	8/20/2015	21-08-2015 to 25-08-2015	Due to OCC Approved Vallur Outage and NCTPS Stage 2 Unit -2 Outage Extension
		26-08-2015 to 31-08-2015	Due to NCTPS Stage 2 Unit-1 Outage Extension