

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for Aug 2016

Issue Date: 20/07/2016

Issue Time: 19:00 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2016 to 21st August 2016	00-24	6106	404	5702	3474	2228	-374	Considering latest LGBR and ISGS outage plan as per 121st OCCM
22nd August 2016 to 31st August 2016					3671	2031		

Limiting Constraint	(n-1) contingency of 400kV Hiriyyur - Nelamangala D/C
----------------------------	--

**National Load Despatch Centre
Transfer Capability between S1-S2 for Aug 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	4/26/2016	01-08-2016 to 31-08-2016	Revision-0
1	7/20/2016	01-08-2016 to 31-08-2016	Considering Latest LGBR & ISGS Outage Plan as per 121st OCCM