

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for December 2015**

Issue Date: 05/10/2015

Issue Time: 1300 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 4th	00:00 Hrs. -24:00 Hrs.	3495	320	3175	3198	0		Operationalization of 530 MW LTA
5th to 6th	00:00 Hrs. -24:00 Hrs.				3147	28		
7th to 11th	00:00 Hrs. -24:00 Hrs.				3224	0		
12th to 31th	00:00 Hrs. -24:00 Hrs.				3135	40		

<b>Limiting Constraint</b>	(n-1) contingnecy of 400kV Udumalpet - Palakkad D/C
----------------------------	---

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for December 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	25-08-2015	01-12-2015 to 31-12-2015	Revision-0
1	05-10-2015	01-12-2015 to 31-12-2015	Operationalization of 530 MW LTA