

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for February 2016

Issue Date: 27/11/2015

Issue Time: 17:20 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2015 to 29th February 2015	00-24	5757	350	5407	3015	2392		

Limiting Constraint (n-1) contingency of 400kV Udumalpet - Palakkad D/C

Note: Maximum Temperature of February-2015(as February-2016 was not available in acuweather or IMD) was considered as reference for Palakkad(34 degrees) & Udumalpet(34 degrees) and added 5 degrees as per NRCE guidelines

**National Load Despatch Centre
Transfer Capability between S1-S2 for February 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	27-11-2015	01-02-2016 to 29-02-2016	Revision-0