

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for January 2016

Issue Date: 05/10/2015

Issue Time: 1300 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2015 to 5th January 2015	00-24	3795	350	3445	2985	460		Operationalization of 530 MW LTA
6th January 2015 to 31st January 2015	00-24	3795	350	3445	2908	537		

Limiting Constraint	(n-1) contingecy of 400kV Udumalpet - Palakkad D/C
----------------------------	---

National Load Despatch Centre
Transfer Capability between S1-S2 for January 2016

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	28-09-2015	01-01-2016 to 31-01-2016	Revision-0
1	05-10-2015	01-01-2016 to 31-01-2016	Operationalization of 530 MW LTA