

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for July 2015

Issue Date: 21/07/2015

Issue Time: 1215 hrs

Revision No. 8

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July	00-24	4700	330	4370	2550	1820		
2nd July	00 - 08 & 19-24	4700	330	4370	2550	1820		
	08-19	4700	330	4370	2550	1820		
3rd July	00-24	4700	330	4370	2318	2052		
4th July to 5th July	00-24	4700	330	4370	2550	1820		
6th	00-17	4700	330	4370	2550	1820		
	17-24	4950	330	4620	2659	1961		
7th	00-24	4950	330	4620	2659	1961		
8th	00 - 12	4700	330	4370	2550	1820		
	12 - 24	4950	330	4620	2659	1961		
9th	00 - 24	4950	330	4620	2659	1961		
10th July to 13th July	00-24	4700	330	4370	2550	1820		
14th July	00-07 & 19 - 24	4700	330	4370	2550	1820		
	07 - 19	3975	330	3645	2550	1095		
15th July	00-07 & 19 - 24	4700	330	4370	2550	1820		
	07 - 19	4610	330	4280	2550	1730		
16th July to 20th July	00-24	4700	330	4370	2550	1820		
21st July 2015	00 - 13	4410	330	4080	2550	1530		
	13 - 24	4700	330	4370	2550	1820		
22nd July to 26th July	00-24	4700	330	4370	2550	1820	290	Due to NCTPS Stage 2 Unit - 2 Outage Extension
27th July	00-24	4700	330	4370	2639	1731		
28th July- 30th July	00-24	4700	330	4370	2719	1651		
31st July	00-25	4700	330	4370	2629	1741		

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	---

**National Load Despatch Centre
Total Transfer Capability for July 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	22-06-2015	01-07-2015 to 31-07-2015	Revised due to LGBR Changes by constituents & Unit Outage Finalised in 108th OCC Meeting and 400kV Tiruvalam-Mettur line-DC, NTPL UNIT-1 commisioning
2	30-06-2015	01-07-2015 to 31-07-2015	Due to Revival of Mettur - Stage 3 Unit -1 and NCTPS Stage 2 Unit -2 Outage & on 2nd June due to 400kV kalivindhapattu - Pugalur -1 SD
3	01-07-2015	02-07-2015	Due to Defferment of 400kV Kalivindhapattu - Pugalur - 1 SD by PGCIL
4	03-07-2015	03-07-2015 to 31-07-2015	Due to TALST2 Unit - 3 Outage Deferment.
5	06-07-2015	06-07-2015 to 07-07-2015	Due to Vallur Unit - 3 Tripping
6	08-07-2015	08-07-2015 to 09-07-2015	Due to Vallur Unit - 1 Tripping
7	13-07-2015	14-07-2015	Due to 400kV MTPS - TVLM - 2 , 400kV Kalivindhapattu - Pugalur - 1 and 400kV Nellore - Alamathy SD
		15-07-2015	Due to 400kV Nellore - Sriperumbudur S/C SD
8	21-07-2015	21-07-2015 to 31-07-2015	Due to NCTPS Stage 2 Unit - 2 Outage Extension