

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for June 2015

Issue Date: 28/02/2015

Issue Time: 2045 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jun 2015 to 5th Jun 2015	00-24	2610	305	2305	2790	0		
6th Jun 2015 to 14th Jun 2015	00-24	2910	305	2605	2898	0		
15th Jun 2015 to 30th Jun 2015	00-24	2910	305	2605	2819	0		

Limiting Constraint	(n-1) contingnecy of 400kV Kolar-Hosur D/C
----------------------------	---

**National Load Despatch Centre
Total Transfer Capability for June 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision