

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for March 2016

Issue Date: 30/11/2015

Issue Time: 1800 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2015 to 31st March 2015	00-24	5764	350	5414	2924	2490		

Limiting Constraint	(n-1) contingnecy of 400kV Udumalpet - Palakkad D/C
----------------------------	--

Note: Maximum Temperature of March-2015(as March-2016 was not available in acuweather or IMD) was considered as reference for Palakkad(37 degrees) & Udumalpet(37 degrees) and added 5 degrees as per NRCE guidelines

**National Load Despatch Centre
Transfer Capability between S1-S2 for March 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	30-11-2015	01-03-2016 to 31-03-2016	Revision-0