

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for May 2016

Issue Date: 21/04/2016

Issue Time: 1100 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2016 to 31st May 2016	00:00 Hrs - 24:00 Hrs	5169	372	4797	3763	1034	-639	Considering Latest LGBR & ISGS Outage Plan as per 118th OCCM , Considering Ambient Temperature of 40 deg for 400kV Udumalpet - Palakkad DC

Limiting Constraint	(N-1) contingency of 400kV Udumalpet - Palakkad D/C
----------------------------	--

**National Load Despatch Centre
Transfer Capability between S1-S2 for May 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	12/23/2015	01-04-2016 to 30-04-2016	Revision-0
1	4/21/2016	01-05-2016 to 31-05-2016	Considering Latest LGBR & ISGS Outage Plan as per 118th OCCM , Considering Ambient Temperarture of 40 deg for 400kV Udumalpet - Palakkad DC