

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for November 2016**

Issue Date: 26/07/2016

Issue Time: 14:00 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st November 2016 to 30th November 2016	00-24	6779	353	6427	3902	2525	0	Revision-0

<b>Limiting Constraint</b>	<b>(n-1) contingency of 400kV Hiriyr - Nelamangala D/C</b>
----------------------------	--