

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for November 2015

Issue Date: 28/07/2015

Issue Time: 2230 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs. -24:00 Hrs.	3805	315	3490	3490	0		
3rd to 4th	00:00 Hrs. -24:00 Hrs.							
5th to 9th	00:00 Hrs. -24:00 Hrs.							
10th to 14th	00:00 Hrs. -24:00 Hrs.							
15th to 29th	00:00 Hrs. -24:00 Hrs.							
30th	00:00 Hrs. -24:00 Hrs.							

Existing LTA/MTOA plus notional LTA/MTOA granted by CTU as per CERC orders dated 16th Feb 2015 and 3rd Jul 2015 in petition nos 92/MP/2014 and 92/MP/2015. Notional LTA/MTOA will be operationalized based on margins available from time to time.

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	--

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for November 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	28-07-2015	01-11-2015 to 30-11-2015	Revision-0