

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for November 2015**

Issue Date: 05/10/2015

Issue Time: 1300 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs. -24:00 Hrs.	4290	315	3975	3085	890		Operationalization of 530 MW LTA
3rd to 4th	00:00 Hrs. -24:00 Hrs.				3294	681		
5th to 9th	00:00 Hrs. -24:00 Hrs.				3146	829		
10th to 14th	00:00 Hrs. -24:00 Hrs.				3366	609		
15th to 29th	00:00 Hrs. -24:00 Hrs.				3565	410		
30th	00:00 Hrs. -24:00 Hrs.				3345	630		

<b>Limiting Constraint</b>	(n-1) contingency of 400kV Mywadi - Palakkad D/C
----------------------------	--

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for November 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	25-07-2015	01-11-2015 to 30-11-2015	Revision-0
1	05-10-2015	01-11-2015 to 30-11-2015	Operationalization of 530 MW LTA