

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for October 2015

Issue Date: 28/06/2015

Issue Time: 1400 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs. -24:00 Hrs.	4040	320	3720	2496	1224		
3rd to 10th	00:00 Hrs. -24:00 Hrs.				2573	1147		
11th to 14th	00:00 Hrs. -24:00 Hrs.	3775		3455	2663	792		
15th to 21st	00:00 Hrs. -24:00 Hrs.				2507	948		
22nd	00:00 Hrs. -24:00 Hrs.				2587	868		
23rd	00:00 Hrs. -24:00 Hrs.				2676	779		
24th to 31st	00:00 Hrs. -24:00 Hrs.				2467	988		

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	--

**National Load Despatch Centre
Total Transfer Capability for October 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	25-06-2015	Whole Month	Revision-0