

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for October 2016

Issue Date: 21/10/2016

Issue Time: 19:00 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2016 to 18th October 2016	00-24	6895	370	6525	3590	2935		
19th October 2016 to 23rd October 2016					3821	2704		
24th October 2016 to 25th October 2016		6360		5990	3821	2169	-535	Due to 400kV Mettur - Thiruvalem DC SD
26th October 2016 to 30th October 2016		6895		6525	3710	2815		
31st October 2016					3916	2609		

Limiting Constraint	(N-1) contingency of 400kV Udumalpet - Palakkad D/C
	(N-1) contingency of 400kV Hosur - Salem D/C for 24th and 25th October

National Load Despatch Centre
Transfer Capability between S1-S2 for October 2016

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	6/24/2016	01-10-2016 to 31-10-2016	Revision-0
1	9/30/2016	01-10-2016 to 31-10-2016	Considering Latest LGBR & ISGS Outage Plan as per 123rd OCCM
2	10/21/2016	24-10-2016 to 25-10-2016	Due to 400kV Mettur - Thiruvallam DC SD