

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for September 2015

Issue Date: 21/08/2015

Issue Time: 1200 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2015 to 5th September 2015	00:00 Hrs-24:00 Hrs	4220	350	3870	2263	1607	265	Due to LGBR Change and new Genrators Outage Plan as submitted in 110th OCCM and network updation
6th September 2015 to 7th September 2015	00:00 Hrs-24:00 Hrs	4220	350	3870	2305	1565	265	
8th September 2015 to 14th September 2015	00:00 Hrs-24:00 Hrs	4045	350	3695	2305	1390	90	
15th September 2015 to 19st September 2015	00:00 Hrs-24:00 Hrs	4045	350	3695	2382	1313	90	
20th September 2015 to 25th September 2015	00:00 Hrs-24:00 Hrs	4045	350	3695	2537	1158	90	
26th September 2015 to 28th September 2015	00:00 Hrs-24:00 Hrs	4045	350	3695	2616	1079	90	
29th September 2015 to 30th September 2015	00:00 Hrs-24:00 Hrs	4045	350	3695	2815	880	90	

Limiting Constraint	(n-1) contingnecy of 400kV Udumalpet - Pallakad D/C upto 7th September 2015 and (n-1) contingnecy of 400kV Kolar-Hosur D/C from 7th to 30th September 2015
----------------------------	---

**National Load Despatch Centre
Total Transfer Capability for Septemeber 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	25-05-2015	01-09-2015 to 30-09-2015	Revision-0
1	26-06-2015	01-09-2015 to 30-09-2015	Revised due to 400kV Mettur - TVLM DC & NTPL Unit - 1 commissioning
2	20-07-2015	01-09-2015 to 30-09-2015	STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
3	21-08-2015	01-09-2015 to 30-09-2015	Due to LGBR Change and new Genrators Outage Plan as submitted in 110th OCCM and network updation