

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for September 2015**

Issue Date: 02/09/2015

Issue Time: 1200 hrs

Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2015	00:00 Hrs-24:00 Hrs	4090	350	3740	2152	1588	0	
2nd September 2015	00:00 Hrs-12:00 Hrs	4090	350	3740	2152	1588	0	
2nd September 2015	12:00 Hrs-24:00 Hrs	4280	350	3930	2261	1669	190	Due to outage of NTECL Vallur unit-1
3rd September 2015	00:00 Hrs-24:00 Hrs	4280	350	3930	2261	1669	190	
4th September 2015	00:00 Hrs-12:00 Hrs	4280	350	3930	2261	1669	190	
4th September 2015	12:00 Hrs-24:00 Hrs	4090	350	3740	2152	1588	0	Due to expected revival of NTECL Vallur unit-1
5th September 2015	00:00 Hrs-24:00 Hrs	4090	350	3740	2152	1588	0	
6th September 2015 to 9th September 2015	00:00 Hrs-24:00 Hrs	4090	350	3740	2194	1546	0	
10th September 2015 to 14th September 2015	00:00 Hrs-24:00 Hrs	3890	350	3540	2085	1455	0	
15th September 2015 to 19st September 2015	00:00 Hrs-24:00 Hrs	3890	350	3540	2162	1378	0	
20th September 2015 to 25th September 2015	00:00 Hrs-24:00 Hrs	3890	350	3540	2317	1223	0	
26th September 2015 to 28th September 2015	00:00 Hrs-24:00 Hrs	3890	350	3540	2396	1144	0	
29th September 2015 to 30th September 2015	00:00 Hrs-24:00 Hrs	3890	350	3540	2595	945	0	

<b>Limiting Constraint</b>	<b>(n-1) contingency of 400kV Udumalpet - Pallakad D/C</b>
----------------------------	--

**National Load Despatch Centre  
Total Transfer Capability for Septemeber 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	5/25/2015	01-09-2015 to 30-09-2015	Revision-0
1	6/26/2015	01-09-2015 to 30-09-2015	Revised due to 400kV Mettur - TVLM DC & NTPL Unit - 1 commissioning
2	7/20/2015	01-09-2015 to 30-09-2015	STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
3	8/21/2015	01-09-2015 to 30-09-2015	Due to LGBR Change and new Genrators Outage Plan as submitted in 110th OCCM and network updation
4	8/31/2015	01-09-2015 to 30-09-2015	Considering NTPL U-2 and outage of Vallur U-3 and NCTPS st2 U-2
5	9/2/2015	02-09-2015 to 04-09-2015	Considering outage of NTECL Vallur unit-1