

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for September 2016

Issue Date: 28/05/2016

Issue Time: 14:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2016 to 30th September 2016	00-24	5405	386	5019	4277	742	0	Revision-0

Limiting Constraint	(n-1) contingnecy of 400kV Hiriyr - Nelamangala D/C
----------------------------	---

**National Load Despatch Centre
Transfer Capability between S1-S2 for September 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	5/25/2016	01-09-2016 to 30-09-2016	Revision-0