

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for August 2018

Issue Date: 13th August 2018

Issue Time: 1600 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2018 to 13th August 2018	00 - 24	8100	490	7610	4530	3080		
14th August 2018 to 31st August 2018	00 - 24	8100	490	7610	4416	3194		STOA margin revised due to planned shutdown of units of KKNP, Simhadri, Vallur, Kalpakkam, TSTPP, NLC-1 Expansion as approved in 146th OCCM of SR
Limiting Constraints (any one or combination thereof)	i. (n-1) of 765/400kV ICT at Tiruvalum.							
	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	iv. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for August 2018

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2018 to 13th August 2018	00-24	3000	90	2910	2742	168		
14th August 2018 to 31st August 2018	00-24	3000	90	2910	2380	530		STOA margin revised due to planned shutdown of units of KKNP, Simhadri, Vallur, Kalpakkam, TSTPP, NLC-1 Expansion as approved in 146th OCCM of SR
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for August 2018
Transfer Capability for Import of S3 for August 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
1	13th August 2018	14-08-2018 to 31-08-2018	STOA margin revised due to planned shutdown of units of KKNP, Simhadri, Vallur, Kalpakkam, TSTPP, NLC-1 Expansion as approved in 146th OCCM of SR	S1- (S2&S3) and Import of S3