

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for August 2017

Issue Date: 29/07/2017

Issue Time: 1900 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2017 to 3rd August 2017	00 - 24	7120	350	6770	4193	2577		
4th August 2017 to 6th August 2017					3974	2796		
7th August 2017 to 10th August 2017					3638	3132		
11th August 2017 to 14th August 2017					3484	3286		
15th August 2017 to 19th August 2017					3393	3377		
20th August 2017 to 22nd August 2017					3318	3452		
23rd August 2017 to 28th August 2017					3396	3374		
29th August 2017					3627	3143		
30th August 2017 to 31st August 2017					3549	3221		
Limiting Constraints (any one or combination thereof)					i. (n-1) of 765/400kV ICT at Tiruvalum.			
	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit							
	v. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	vi. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for August 2017

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2017 to 3rd August 2017	00-24	3000	80	2920	1944	976		
4th August 2017 to 6th August 2017					2075	845		
7th August 2017 to 10th August 2017					2110	810		
11th August 2017 to 14th August 2017					2067	853		
15th August 2017 to 19th August 2017					2088	832		
20th August 2017 to 22nd August 2017					2072	848		
23rd August 2017 to 28th August 2017					2052	868		
29th August 2017					2153	767		
30th August 2017 to 31st August 2017					2172	748		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for August 2017
Transfer Capability for Import of S3 for August 2017

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
1	7/29/2017	Whole Month	Revision - 1	