

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for December 2018**

Issue Date: 07/12/2018

Issue Time: 1300 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2018 to 18th December 2018	00 - 24	7870	450	7420	3451	3969		
19th December 2018 to 24th December 2018	00 - 24	7870	450	7420	3639	3781		
25th December 2018 to 31st December 2018	00 - 24	7870	450	7420	3721	3699		
Limiting Constraints (any one or combination thereof)	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS							
	ii. (n-1) of 765/400kV ICT at Tiruvalum.							
	iii. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	v. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	vi. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for December 2018**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2018 to 8th December 2018	00-24	3010	90	2920	2643	277		
9th December 2018	00 -10	3010	90	2920	2643	277		
	10 - 24	2510	90	2420	2643	0	-500	Due to 230kV Tirunelveli - Edamon D/C Emergency Outage.
10th December 2018 to 18th December 2018	00-24	3010	90	2920	2643	277		
19th December 2018 to 24th December 2018	00-24	3010	90	2920	2717	203		
Limiting Constraint (any one or combination)	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

