## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for December 2022

Issue Date: 26/08/2022 Issue Time: 2200 Hrs Revision No. 0

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) *	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st December 2022 to 31st December 2022	00 - 06 and 18 -24Hrs	8200	450	7750	3795	3955			
	06 - 18 Hrs	8200	450	7750	3975	3775			
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT								
	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS								
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

<sup>\* 50%</sup> of Wind export LTA Considered for STOA margin

<sup>\*</sup>Solar export LTA considered in the solar period

## Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for December 2022

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2022 to 31st December 2022	00-24	3400	90	3310	2812	498		
Limiting Constraint	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin ss will lead to over-loading of the Other ICT							
(any one or	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
combination thereof)	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for December 2022 Import Capability of S3 for December 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-08-2022	01-12-2022 to 31-12-2022	Revision-0	-