

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for February 2018**

Issue Date: 09/02/2018

Issue Time: 1100 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2018 to 2nd February 2018	00 - 24	7960	450	7510	4038	3472		
3rd February 2018 to 28th February 2018		6830		6380		2342		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit							
	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit							
	iv. (n-1) of 765/400kV ICT at Tiruvalum.							
	v. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	vi. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for February 2018**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2018 to 9th February 2018	00-24	2960	80	2880	2708	172		
10th February 2018	00 -0900	2960		2880		172		
	0900 - 2400	2460		2380		0	-500	Due to the SD of 400kV Uduamalpet - Palakkad - 2
11th February 2018 to 28th February 2018	00-24	2960		2880		172		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for February 2018**  
**Transfer Capability for Import of S3 for February 2018**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor</b>
0	10/26/2018	01-02-2018 to 28-02-2018	-	-
1	2/2/2018	03-02-2018 to 28-02-2018	Due to the SD of 400kV Somnahalli Hosur S/C line	S1-(S2&S3)
2	2/9/2018	2/10/2018	Due to the SD of 400kV Udumalpet - Palakkad -2 line	Import of S3